

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				I. CONTRACT ID CODE J	PAGE OF PAGES 1   2
2. AMENDMENT/MODIFICATION NO. 0003	3. EFFECTIVE DATE 16-Sep-2004	4. REQUISITION/PURCHASE REQ. NO. W34GM1-4222-0001	5. PROJECT NO.(If applicable) FE21102-4J		
6. ISSUED BY CODE DIRECTORATE OF CONTRACTING ACA, FORT CAMPBELL BLDG 2174 13 1/2 ST FORT CAMPBELL KY 42223-1100		7. ADMINISTERED BY (If other than item 6) CODE  <b>See Item 6</b>			
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X	9A. AMENDMENT OF SOLICITATION NO. W91248-04-Q-0081
				X	9B. DATED (SEE ITEM 11) 26-Aug-2004
					10A. MOD. OF CONTRACT/ORDER NO.
					10B. DATED (SEE ITEM 13)
CODE		FACILITY CODE			
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) Solicitation W91248-04-Q-0081, Replace Air Handling Units in Building 95, Fort Campbell, Kentucky is amended as follows:  <p style="text-align: center;">SEE ATTACHED SHEET</p>					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
			TEL: _____ EMAIL: _____		
15B. CONTRACTOR/OFFEROR  _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA  BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED  16-Sep-2004	

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

**SUMMARY OF CHANGES**

Solicitation W91248-04-Q-0081, Replace Air Handling Units in Building 95, Fort Campbell, Kentucky is amended as follows:

a. The following information about specs for the cooling, CFM and heat capacities and change in the size of UNIT #2 are added to the specifications:

UNIT #1 – The main unit in the basement is cooling only with approximately 15 tons of total cooling capacity. The Fan CFM is 6900 and 24 gpm.

UNIT #3 and #4 – Both have heat and cooling, total cooling capacity is approximately 9 tons, CFM is 4850, 13gpm with heating capacity of 330MBH and 33 gpm. These units can remain as specified in the solicitation.

UNIT #2 – Is cooling only and shall be a 60SVW series, Vertical Hydronic Belt Drive Blower-coil Unit as manufactured by First Co., or equal. Approximate total cooling capacity is approximately 5 tons, approximately at 7gpm, a minimum 4 row chilled water coil, 2” filters and approximately 2000CFM. Motor – 208/230 volt 3 phase approximately  $\frac{3}{4}$  horsepower.

All return air filter sections and grills may be re-used. Contractor shall ensure loose components are secured and provide transitions to the new air handler to ensure full coil coverage for air movement and flow. Transitions shall be fabricated with 24 gauge galvanized sheet metal IAW SMACNA standards.

b. The required response date/time has changed from 17 September 2004 at 01:00 PM CT **TO READ** 24 September 2004 at 01:00 PM CT.

(End of Summary of Changes)